



Steven Levy Enterprises, Inc.
1412 Pennsylvania
South Houston, Texas 77587
Phone: (713) 910-4337 Fax: (713) 910-2039

Steven Levy Enterprises, Inc. is accepting bids on behalf of our clients for the following material:

SLE 21-044

Electrical Component & More Sale

Eaton, Cutler Hammer, Siemens, Allen Bradley & More

Sealed Bid Sale

Bidder Information

Company: _____

(Signature)	(Printed Name)	(Date)	(Phone Number)
Inspected Surplus	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
(Check One)			

Subject material to be sold on "AS IS / WHERE IS" basis.
 Material is sold FOB Steven Levy Enterprises, Inc. located at 1412 Pennsylvania, South Houston, Texas.

BID DUE: December 1st, 2021 @ NOON

To inspect material or for additional information contact:

Steven Levy Enterprises, Inc. (713) 910-4337
 Inspection Time 7:30 - 3:00 M-F
 Available for inspection Immediately thru Bid Close
 We are happy to pick up out-of-town buyers at Hobby Airport (HOU)

Seller reserves the right to reject any and all bids. Only the successful bidder will be notified of awards. Payment is due upon notification of award. All sales will be charged sales tax unless resale tax exemption certificate accompanies payment or is on file with Steven Levy Enterprises, Inc. Equipment is to be removed from property within ten (10) days at buyer's expense. Seller description of material is best available information, seller provides no express warranties and/or guarantees as to the quantity, quality, and/or fitness for any use or purpose. Steven Levy Enterprises, Inc. encourages all bidders to inspect material prior to placing bids.

******PLEASE SUBMIT THIS COVER PAGE WITH ALL BIDS******

Please visit our web site www.slevysurplus.com for more available equipment.

SLE 21-044 Electrical Component & More Sale

Company: _____
 Bidder: _____
 Phone: _____

LOT #	PART #	DESCRIPTION	QTY	BID
IIP 1	SG3A0030KK0C	HAMMOND XFMR 30KVA, 3-PH, HIGH EFFICIENCY, TYPE DOE2016, 480 PRI, 277/480VAC SEC, 60HZ, 150 DEG C RISE, COPPER WINDINGS, (2)-2-1/2% TAPS ABOVE, (4)-2-1/2% TAPS BELOW, UL. 28.8"H X 25.8"W X 23.8"D, WEIGHT 355LBS, VENTILATED N3R ENCLOSURE	1	\$
IIP 2	FFLED39SFYW	39W LED FLOODLIGHT (REPLACES 150W MH). 3000K COLOR TEMP, WHITE FINISH	1	\$
	36361P00000417	SEC. DISCONNECT INTERLOCK OVER-RIDE - ARM	13	
	VMV5L2TWDWM2/UNV1	LED LUMINAIRES, EXPLOSION PROOF CL 1 DIV 2 EXTERIOR LIGHT, 3/4" WALL MOUNT THRU FEED, 5L SERIES, VOLTAGE RANGE 100-277V, 60HZ, 98WATTS INPUT POWER, 0.98 INPUT AMPS (MAX), 108-250VDC RANGE, 0.85 POWER FACTOR.	8	
IIP 3	VMV7L2TW/UNV1	EXT WALL MTD LED LIGHT	16	\$
IIP 4	230113-05-00-1	ENCLOSURE,INDOOR,FREE STANDING,HOFFMAN TYPE 12, FLOOR MOUNT. P/N=A606010LP W/O BACK PAN, EXTERIOR PAINT CODE= ANSI 70.	1	\$
IIP 5	230113-02-00-1	ENCLOSURE,INDOOR,FREE STANDING,HOFFMAN TYPE 12, FLOOR MOUNT. P/N=A606010LP W/O BACK PAN, EXTERIOR PAINT CODE= ANSI 70.	1	\$
IIP 6	3CPTD3-60-75-4161B	TRANSFORMER,CONTROL POWER,CAST COIL,CPT ITI 75KVA 3P 60HZ	1	\$
IIP 7	3CPTD3-60-75-4161B	TRANSFORMER,CONTROL POWER,CAST COIL,CPT ITI 75KVA 3P 60HZ	1	\$
IIP 8	237469-03-00-4a	BATTERY CHARGER.	1	\$
IIP 8	238669-03-00-4a	BATTERY CHARGER.	1	\$
IIP 9	238670-03-00-4A	BATTERY CHARGER.	1	\$
IIP 9	238671-03-00-4A	BATTERY CHARGER.	1	\$
IIP 10	3PT3-60-422FFF	PT/ITI, 4200/120VAC, 3PH,	12	\$
	786-402MR	TRANSFORMER,CURRENT,SINGLE PHASE,GE/ITI MODEL 786 MRCT, RATIO 4000:5A, FREQUENCY 50-400HZ, INSULATION LEVEL 0.6KV, BIL 10KV, RELAY CLASS C400, ANSI METER CLASS 0.3B1.8,	6	

IIP 11	a20-3	INSULATOR STANDOFF MEISTER INT. PART NUMBER A20-3 - 13.2KV 4.5"W PORCELAIN STANDOFF, 6"H, (4)3/8-16 ON 2"	9	\$
	0329B8009G001	Compartment Roll-Out sec disconnect	1	
	1791P02	GROUNDING STUD COVER	4	
	90267P02	BUS SUPPORT INSULATOR 2000A 1(5/8 X4) CU	1	
	26264P00001604	SUPPORT STRUCTURE.BUS...RISER BUS BAR SUPPORT - CHANNEL TYPE	30	
	6350-S104X2	MAR-BAL 3 1/2" HEIGHT, STANDOFF INSULATOR	54	
	9L12PPM015S	SURGE ARRESTOR INTERMEDIATE CLASS, POLYMER, 12.7KV MCOV, STUD MOUNTED	3	
	EPC12-001-300E07T-03	BUSHING, DEAD-BREAK, 21.1KV/600A	3	
	FG30909020	MFG COMP & SUPPLIES,MACHINED COMPONENT,,1/2" X 6" UPPER BUS SUPPORT	36	
	6350-S104X2	MAR-BAL 3 1/2" HEIGHT, STANDOFF INSULATOR	68	
	02-000-022	INSULATOR CAST CYCLO 5KV, E01	24	
	402384H02	THRU-WALL CABLE BUSHING	4	
IIP 12A	a480r9r-1	FUSE CLF 4.8KV 9R 200A	5	\$
	A480R2R-1	Fuse	3	
	15CLE-125E	FU/CUTLER- HAMMER,15.5KV,	3	
	TRM8	FUSE, 8AMP 250V,FERRAZ	10	
	38CAVH0.5E	BUSSMANN FUSE TYPE CAVH 38 KV, 0.5E, 40KA IR, 17.32 IN (440 MM) LENGTH X 1.63 IN (41.3 MM) DIAMETER	2	
	A055F1D0R0-30E	FUSE CLF 5.5KV 30E 63KA	3	
	A055F2D0R0-400E	FUSE CLF 5.5KV 400E 63KA	3	

IIP 12B	5bcls-4r	FUSE CLS-4R BOLT-IN TYPE, EATON C-H ,5KV, 130A,	1	\$
	5bhle-50e	FUSE HLE-50E 5.5KV BOLT-IN TYPE, EATON C-H	1	
	5cls-12r	*fuse	1	
	a480r3r-1	FUSE,MEDIUM VOLTAGE,,FERRAZ SHAWMUT MV FUSE R-RATED, 5.5KV, 63KA IR SYMETRICAL, 3R, 100A AT 40 DEGREE OF C. UL RECOGNIZED.	1	
	a480r4r-1	FUSE CLF 4.8KV 4R 130A	1	
	a480r5r-1	#N/A	2	
	a480r12r-1	FUSE CLF 4.8KV 12R 230A	3	
	a480r18r-1	FUSE CLF 4.8KV 18R 390A	3	
	A055B2D0R0-600E	FUSE CLF 5.5KV 600E 63KA	3	
	5BHLE-125E	FUSE HLE-125E 5.5KV BOLT-IN TYPE, EATON C-H	2	
IIP 13	CT230-251	AMRAN CURRENT TRANSFORMER 600V, 250:5A RATIO, 10KV BIL, CLASS C20	3	\$
	CT230-601	AMRAN CURRENT TRANSFORMER 600V, 600:5A RATIO, 10KV BIL, CLASS C50	8	
	ct230-601mr	TRANSFORMER, CURRENT,AMRAN, 600V, 600:5A MULTI-RATIO, 10KV BIL, CLASS C50	2	
	ct230-301	AMRAN CURRENT TRANSFORMER 600V, 300:5A RATIO, 10KV BIL, CLASS C20	1	
	125-sd-38591	GFCT/ITI 2000/1 RATIO	1	
	21-201	CT/ITI 200/5A, C20	11	
	ct230-151	AMRAN CURRENT TRANSFORMER 600V, 150:5A RATIO, 10KV BIL, CLASS C20	6	
	ct230-201	AMRAN CURRENT TRANSFORMER 600V, 200:5A RATIO, 10KV BIL, CLASS C20	9	
	21-401	CURRENT TRANSFORMER	1	
	3PT3-60-422FFF	PT/ITI,4200/120 VAC, 3PH	4	
	SNCP21853	TRANSFORMER 075-2000-B MVCT 5V 2000VA 1	1	
	3VA9234-0JA12	Siemens CB 3VA 250A Steel Lugs, 4 per set	16	
	SPA-ZF-AA-20	PLASTIC SIGNAL TRANSFER FIBER FOR	1	
	CT230-501	AMRAN CURRENT TRANSFORMER 600V, 500:5A RATIO, 10KV BIL, CLASS C20	3	
87C1260G17	CONTACTOR,MEDIUM VOLTAGE,WIRING HARNESS 400A OR 800A EATON C-H STYLE 3173 125 C	6		

IIP 14	ECL03C1ABA	30 AMP LIGHTING CONTACTOR, C-H LIGHTING CONTACTORS	1	\$
	CCP-1-30CC	FUSE HOLDER, BUSSMANN, 30A 600VAC 1 POLE, CLASS CC, 200KA SCCR, UL 98 LISTED.	17	
	9084A17G01	EATON J-Auxillary	5	
	PX-PMBD	ADAPTER PROJECTION MOUNT 2"	2	
	C0750E2AFB	CPT/CH,230-460/115V,	1	
	HM25030-XSR	BUSSMANN SERIES FUSE BLOCK	7	
	10250T2411-2	SELECTOR-PUSH SWITCH W/NO	1	
	10250T197LWP2D	EATON INDICATING LIGHT	17	
	10250T197LAP2D	EATON INDICATING LIGHT	31	
	10250T197LGP2D	EATON INDICATING LIGHT	33	
	10250T197LRP2D	EATON INDICATING LIGHT	33	
	UNS15070B0D0A1A	DISTRIBUTION CLASS, POLYMER, 12.7KV MCOV, STUD MOUNTED	6	
	UNS06040B0D0A1A	SURGE ARRESTOR DISTRIBUTION CLASS, POLYMER, 5.1KV MCOV, STUD MOUNTED	6	
	CGB599	CROUSE-HINDS/COOPER POWER CABLE CONNETOR	2	
IIP 15	AEAB3036DS	DISCONNECT SWITCH, 480V, 3PH, NON FUSED, 30A, CLASS 1, DIV 2	2	\$
	1C742	DAYTON SINGLE PANEL	5	
	1C742	DAYTON SINGLE PANEL	7	
	PL9900P-ENC120-HI-6-5A-A-S-E1-D1-XX	GE, ADVANCED POWER QUALITY METERING SYSTEM	1	
IIP 16	1222P01	VAULT HANDLE CASTING (RIGHT SIDE) BLACK	356	\$
	43620885	MILWAUKEE SIDE HANDLE, RED SIDE HANDLE FOR DRILL MOTOR 0234-1. #6183608	30	
	S14810	SUBASSEMBLY,MECHANICAL,,CORBIN HANDLE, SCREEN	50	
IIP 17A	C9688A88G01	TEST SWITCH, ABB, FT-1	2	\$
	129A514G01	Test Switch, ABB, FT-1 Style, 10 Poles 4P/6C, Black Cover,	4	
IIP 17B	1734-APB	POINT I/O PROFIBUS ADAPTER MODULE,	6	\$
	TEB122035WL	CB-MC/GE E150-LINE 2P 35A	11	
	TEB122015	CIRCUIT BREAKER, MOLDED CASE AC, PANEL BOA	7	
	700-HA32A1	ALLEN BRADLEY BULLETIN	6	
	606B029A13	AUXILIARY RELAY/W/TYP	1	

IIP 18	0209B5163P001	SWITCH, GE PV BKR - SHALLCO 12862-2	1	\$
	2409C	24 AM SW 3CT END OF CKT	4	
	PMP-25	LOAD CONTROLS INC.	2	
	24305B	4 POSITION SELECTOR SW.	8	
	2458D	SWITCH/PUSHBUTTON,CONTROL,,ELECTROSWITCH SERIES 24, BREAKER CONTROL SWITCH, 6 CONTACT DECKS, SPRING RETURN TO POS 3, PULL-TO-LOCK IN POS 1,	1	
	SPH-01P	HOUSING / CORNING WALL MOUNT SINGLE PANEL ANIXTER #313351	1	
	SEN6P1C1A10XB6B6	SUBASSEMBLY,ELECTRICAL,,SENTRY, BREAKER CONTROLLER, 1ARM, 2BS6.	1	
	SEN6P1C1B6B6B6B6	SUBASSEMBLY,ELECTRICAL,,SUBASSEMBLY,ELECTRICAL,,SENTRY WITH 4 10041-1 THERMAL MONITORING CARDS WITH 6 CHANNELS PER CARD. POWER IN: 120-250VAC OR DC, EIA-485 COMMS	4	
	PM130EH-PLUS-60HZ-5-ACDC-A04	METER/SATEC, MULTIFUNCTION,	2	
	7803D	ELECTRO SWITCH	1	
	PBO-MCRD	SWITCH/PUSHBUTTON,CONTROL,,MOMENTARY NON-ILLUMINATED PUSHBUTTON, BLACK POLYESTER (TYPE 4X) CLAMP RING, RED MUSHROOM CAP	1	
	KUEP-11D15-125	RELAY,DISCRETE,CONTROL,RELAY/P & B/TYCO,	12	
	M22-DZ-B-GB14	PUSHBUTTON EATON MECHANICAL RESET	3	
	5278C	RECEPTACLE,NON HAZARDOUS,INDOOR,HUBBELL FLANGED INLET, NYLON CASING, BACK WIRED, WHITE COLOR.	3	
	7012pb	RELAY.AGASTAT	11	
	751001A0X0X0X860200	RELAY,PROTECTION,MULTIFUNCTION,SEL-751 FEEDER PROTECTION RELAY, STD FIRMWARE,	2	

IIP 19	8131-01	COMPUTER,HARDWARE,SERVER COMPONENT,SMALL FORM-FACTOR PLUGGABLE (SFP), 1000BASE-SX	2	\$
	FVLU120LW-PLLWE	PILOT LIGHT/CONTROL	224	
	ECL30UD03-S	AC/DC CONVERTER 5V 12V 30W	2	
	P2SIL3DSES	RELAY, SAFESERIES, WEIDMULLER, 24VDC, -15/+20%, 35mA SWITCHING CURRENT, 5A CONTACT RATING, (2) NO CONTACTS.	5	
	psr-scp-24dc/fsp/1x1/1x2	RELAY,PROTECTION,MULTIFUNCTION,RELAY/PHOENIX CONTACT,	8	
	VTAIE22000G400	BITRONIC VOLTMETERS OPEN DELTA TYPE	2	
	t675a1565	TEMPERATURE CONTROLLER, WITH 1SPDT SWITCH, REMOTE MOUNTED SENSING ELEMENT, ADJUSTABLE DIFFERENTIAL, RANGE 0-100 DEG.F, FOR 277VAC OPERATION.	14	
	CG-37100S	CABLE,POWER MULTI CONNECTOR,600V,EGS CONNECTOR, 5/8 NO SUBS. 1"	1	
	KRPA-11DN-24	POTTER AND BRUMFIELD PLUG-IN AUX RELAY, 2 FORM C CONTACTS, 24VDC COIL INPUT, AgCdO WITH INDICATOR.	21	
	101-00201A	B1 REPEATER, PROFIBUS DP, INPUT VOLTAGE 19 TO 28VDC, 65mA @ 24VDC CURRENT, 2- INPUT/2-OUTPUT, DB9 CONNECTOR PORT. PROCENTEC	1	

IIP 20A	23231p00050738	TORSION SPRING FOR R/O DOOR INTERLOCK	12	\$
	66738p01	SUPPORT RIVET .438 DIAMETER	30	
	YA282N	LUG, 4/0 AWG, DOUBLE HOLE, 1/2" STUD, 1.75 SPACING, LONG BARREL (BURNDY YA282N)	4	
	43608P66	GEAR BOX RACKING GEAR	2	
	1798G06	FLEX CONNECTOR FOR 2 GAP BETWEEN BARS	1	
	28283P81188118	COMPARTMENT.ROLL-OUT...GROUNDING ROD FOR 38KV ROLLOUT	4	
	3043736	BRACKETS	10	
	CL-4-BLPL-4.00	BALL PIN	18	
	49492P00003075	RACKING ARMS	43	
	FH-20-50	CROMPTON INSTRUMENTS SHUNTS, SWITCHBOARD, 20A, 50MV, FH SERIES.	3	
	PBHD4-750	ILSCO, POWER BLOCK, (4) 750kcmil-2, AL9CU, (2) 3/8" MOUNTING HOLES.	6	
	PBHD2-750	ILSCO, POWER BLOCK, (2) 750kcmil-2, AL9CU, (2) 3/8" MOUNTING HOLES.	12	
	CP-RJ45	LUG,FERRULE,,BLANKING PLUG/RICHCO, INC. FOR RJ45 CONNECTOR, GREY.	10	
	49492P00003066	RACKING HANDLE	27	
	FIT221-1/4X5/8	HEAT SHRINK TUBING-BLACK	10000	
	50301P20	IGUS SLIDER- MOUNTING BASE	29	
	28283P81185118	COMPARTMENT.ROLL-OUT...PRIMARY	23	
	23231P00060909	PIN AR DOOR ALIGNMENT	509	
	15151p10000088	LIFT OFF DOOR HINGE SPACER	89	
	26262P00000141	PIN BOSS 3 POINT LATCH AR DOOR	672	
2NPA1	3/4 X 1 RUBBER MOTOR MOUNT, GRAINGER _ACKLANDS ITEM# GGM-2NPA1	78		
233362-01-00-115	CIRCUIT BREAKER,ACCESSORY,KEY INTERLOCK	1		
9540k46	HARDWARE,FASTENER,STANDARD,HARDWARE,FASTENER,STANDARD,NON METALLIC PART,	150		
49492P00000744	ACCESSORIES.BREAKER.REMOTE RACKING DEVICE..1" SPACER	73		
IIP 20B	8612.05	RITTAL; SYSTEM CHASIS FOR TS 8 ENCLOSURE 500mm(20"); 4 PIECES	1	\$
	VLF-EZ-24X30	SUBASSEMBLY,MECHANICAL,,24" X 30" STAINLESS STEEL GLASS VISION FRAME	4	
	915900043	KIT,MOUNTING,BULLET GPS ANTENNA	3	
	26263P00000115	HINGE BARREL ROLLED	200	
	49492P00000677	SMOOTH -FINISH ALUMINUM KNOB	10	
IIP 21	PTW3-2-60-242FF	PT/ITI,2400/120V WITH	11	\$
IIP 22	1TDT2	DAYTON PSC BLOWER, 115VAC, FULL LOAD AMPS 2.05, SINGLE PHASE, 50/60 HZ	10	\$

IIP 23	USM2I	FUSE HOLDER, GOULD	31	\$
	9F61BWW457	FUSE CLIP - SIZE C	2	
	211769-1	FEMALE - AMP SQ FLANGE	28	
	09330102701	DISCONNECT, HAN E FEMALE	20	
	20317	FUSE BLOCK MERSEN 30A, 250V, 2P, SCREW, CLASS H	34	
	BMM603-2SQ	BUSSMANN/COOPER 2P/30A 600V FUSE BLOCK	15	
	9330242701	ELECTRICAL COMPONENT,OTHER,,OBSOLETE PART NUMBER USE 09-33-0242701	58	
	HGA11S52	RELAY,DISCRETE,CONTROL,GE GENERAL PURPOSE AUXILIARY RELAY, SURFACE MOUNT, FRONT CONNECTED, SOLID COVER.	1	
	9F61BNW750	GE LIVE PARTS - SIZE D	6	
	5431-8201-000B	ASM, CONTACT BLOCK	148	
	6SMLC	Adapter Kit – Includes (1) 6-Port LC/UPC Adapter Module	17	
	27E893	P&B Socket for KU Series Panel Plug-in Relay, DIN Rail Mounted.	24	
	16-S1	SECONDARY CONTACT BLOCK/	186	
	BT855	Test Switch, MPS, UTS1 Style, Black Cover, Screw Terminals, Arrangement C-C C-C C-C C-C C-C	1	
16-S1	SECONDARY CONTACT BLOCK/	480		
IIP 24	T600-2246	CHANCE/HUBBELL TEMPORARY GROUND SET,	6	\$
IIP 25	GE30MBDC4010B	PANELBOARD, GE, TYPE AE,	2	\$
IIP 26	PDRSS232UNVEB81U	LIGHT,NON HAZARDOUS,INDOOR,INTERIOR FLUOR LIGHT, COOPER LIGHTING- METALUX, 120-277 VAC	242	\$